

THIRD PARTY INSPECTION CERTIFICATE

Name and address of the manufacturer : TANKEEN ENERGY LTD.ŞTİ / Dörtyol-HATAY

Ordered By TANKEEN ENERGY LTD.ŞTİ
Description of the pressure equipment: 20 m³ LPG Storage Tank
Scope of inspection Inspection Test Plan / TKN-23-015
Manufacturer No TKN-24-2004
Hydrostatic Test Report No TKN-FQ-0153 / 2
Tank Drawing No TE-20S-LPG-2
Tank Design Code ASME SEC VIII Div.2
Design Pressure and Temperature 22 bar - -20 / + 70 °C
Test Pressure and Date 34 bar - 02.06.2024
Radiography Examination Report No 2420087 RT-081
Magnetic Particle Examination Report No 2420087 MT-007
Ultrasonic Examination Report No 2420087 UT-015
Shell Plate Material Quality and Certificate No P355NL1- 350665 (Heat No)
24X230427514 (Certificate No)
Head Plate Material Quality and Certificate No P355NL1- 350652 (Heat No)
24X230427512 (Certificate No)
Mark-Stamp Hard Stamp On Manhole

In compliance with the instructions received from TANKEEN ENERGY LTD.ŞTİ, our inspector attended at manufacturer's premises according to reference documents in order to perform above mentioned inspection.

The manufacturer declares that the product identified above has been manufactured, tested, examined and supplied in conformity with the requirements of the order. The tests and examinations carried out under the supervision of SGS inspectors, within the scope of its General Conditions, have been found in compliance with the technical specifications of the purchase order.

This certificate is not valid without attached documents which contain details of production methods, chemical analysis, mechanical properties, NDT results or any additional inspection results.

This document is issued by the Company under its General Conditions of Service printed overleaf. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any other holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

This certificate supersedes our previous Certificate No. 0252/IN-IST-25

Authorized Specialist: Erhan Arık, Mechanical Engineer

Issued in Istanbul

SGS Supervise Gözetme Etüd Kontrol Servisleri A.Ş.
Member of the SGS Group (Société Générale de Surveillance)
Bağlar Mah. Osmanpaşa Cad. No.95 İstanbul Plaza
Güneşli 34209 İstanbul Turkey
t: 90.212.3684000 (Pbx)
f: 90.212.2964782
e: sgs_turkey@sgs.com

For and on behalf of
SGS Supervise Gözetme Etüd
Kontrol Servisleri A.Ş.

ERSİN

SGS

Page 1 of 1

F150201M

SGSPAPER
20433816

